



April 20, 2015

IRON CITY ENTERPRISES, INC.
TOM NEMETZ
N 2404 HWY. 41
MENOMINEE MI 49858

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: IRON CITY ENTERPRISES, INC.
Product Name: SEPTIC, HOLDING OR PUMP
Model Number(s): 1000
(36 IN. L.L., 28.8 GAL/IN., 48 IN. MAX. DEPTH OF BURY, 497 GPD. WHEN USED
AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER; TANK DIMENSIONS (OD) = 117 IN. L X 67 IN. W X 53 IN. H; SEE
ATTACHMENT FOR GALS./IN. @ ONE-INCH INTERVALS)
Product File No: 20150069

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2020.

This approval supersedes the approval issued on 3/12/2010 under product file number 20100087.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.
- Bedding: Tanks must be placed on soils capable of bearing the weight of tank and its contents, when full. Soft soils or bedrock must have 3 inches of tamped material, sand or gravel, 100% of which passes ½ -inch screen.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S., POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:
www.surveymonkey.com/s/dspscustomersatisfaction